


LUMINAIRE PHOTOMETRIC TEST REPORT


NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /

DATA OF LAMP		PHOTOMETRIC DATA Eff: 11.29 lm/W			
MODEL	2835	Imax(cd)	42.93	S/MH(C0/180)	1.26
NOMINAL POWER(W)	12	LOR(%)	113.2	S/MH(C90/270)	1.18
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	124.49	η UP,DN(C0-180)	0.0,52.3
NOMINAL FLUX(lm)	110	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.1,60.8
LAMPS INSIDE	1	η up(%)	0.1	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	24	η down(%)	113.1	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT: lx)



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	$\%lum, lamp$
10	42.07	41.45	41.18	41.45	41.91	42.53	42.73	42.52	0- 10	4.044	4.044	3.25,3.68
20	39.89	38.69	38.11	38.66	39.59	40.72	41.10	40.71	10- 20	11.57	15.62	12.5,14.2
30	36.31	34.63	33.72	34.53	35.89	37.43	37.96	37.45	20- 30	17.51	33.13	26.6,30.1
40	31.54	29.51	28.37	29.36	31.02	32.90	33.31	32.90	30- 40	21.08	54.21	43.5,49.3
50	25.88	23.62	22.32	23.43	25.27	27.36	27.76	27.35	40- 50	21.87	76.07	61.1,69.2
60	19.59	17.30	15.98	17.09	18.95	21.13	21.55	21.13	50- 60	19.95	96.02	77.1,87.3
70	12.98	10.75	9.451	10.43	12.32	14.56	15.06	14.52	60- 70	15.68	111.7	89.7,102
80	6.065	4.030	2.876	3.792	5.420	7.676	8.374	7.684	70- 80	9.656	121.4	97.5,110
90	0.0034	0.0458	0	0.0603	0.0555	1.131	1.699	1.019	80- 90	3.012	124.4	99.9,113
100	0	0.0000	0	0.0114	0.0326	0.0473	0	0	90-100	0.1129	124.5	100,113
110	0	0	0	0	0.0032	0.0131	0	0	100-110	0.0080	124.5	100,113
120	0	0	0	0	0	0	0	0	110-120	0.0004	124.5	100,113
130	0	0	0	0	0	0	0	0	120-130	0	124.5	100,113
140	0	0	0	0	0	0	0	0	130-140	0	124.5	100,113
150	0	0	0	0	0	0	0	0	140-150	0	124.5	100,113
160	0	0	0	0	0	0	0	0	150-160	0	124.5	100,113
170	0	0	0	0	0	0	0	0	160-170	0	124.5	100,113
180	0	0	0	0	0	0	0	0	170-180	0	124.5	100,113
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:shan
Test Date:2018-09-06

γ Range: 0 - 180DEG
 γ Interval: 2.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity:45.0%
Test Distance:6.950m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	Coefficients of Utilization(CU)															
0.0	1.35	1.35	1.35	1.32	1.32	1.32	1.26	1.26	1.26	1.20	1.20	1.20	1.15	1.15	1.15	1.13
1.0	1.17	1.12	1.07	1.14	1.10	1.06	1.09	1.06	1.02	1.05	1.02	.99	1.01	.98	.96	.94
2.0	1.02	.94	.87	.99	.92	.86	.95	.89	.84	.92	.86	.82	.88	.84	.80	.78
3.0	.89	.79	.72	.87	.78	.71	.84	.76	.70	.81	.74	.69	.78	.72	.68	.65
4.0	.79	.69	.61	.77	.68	.60	.74	.66	.59	.72	.64	.59	.69	.63	.58	.55
5.0	.70	.60	.52	.69	.59	.52	.66	.58	.51	.64	.57	.51	.62	.55	.50	.48
6.0	.63	.53	.46	.62	.52	.45	.60	.51	.45	.58	.50	.44	.56	.49	.44	.42
7.0	.57	.47	.40	.56	.47	.40	.55	.46	.40	.53	.45	.39	.51	.44	.39	.37
8.0	.52	.42	.36	.51	.42	.36	.50	.41	.35	.48	.41	.35	.47	.40	.35	.33
9.0	.48	.39	.32	.47	.38	.32	.46	.38	.32	.45	.37	.32	.43	.37	.32	.29
10.0	.44	.35	.29	.44	.35	.29	.42	.34	.29	.41	.34	.29	.40	.34	.29	.27



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

WEC AND CCEC

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /

pcc	80%			70%			50%			30%			10%			0	
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
ρfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.362	.206	.065	.354	.202	.064	.339	.194	.062	.325	.187	.060	.312	.181	.058		
2.0	.338	.185	.057	.331	.182	.056	.317	.176	.055	.305	.171	.054	.293	.166	.052		
3.0	.311	.165	.050	.305	.163	.049	.293	.159	.048	.282	.154	.047	.272	.150	.047		
4.0	.286	.149	.044	.280	.147	.043	.270	.143	.043	.260	.140	.042	.251	.136	.042		
5.0	.264	.134	.039	.259	.133	.039	.249	.130	.038	.241	.127	.038	.233	.124	.037		
6.0	.244	.122	.035	.240	.121	.035	.231	.119	.035	.224	.116	.034	.216	.114	.034		
7.0	.227	.112	.032	.223	.111	.032	.216	.109	.031	.209	.107	.031	.202	.105	.031		
8.0	.212	.103	.029	.208	.102	.029	.202	.101	.029	.195	.099	.029	.189	.097	.028		
9.0	.198	.096	.027	.195	.095	.027	.189	.093	.027	.183	.092	.026	.178	.091	.026		
10.0	.186	.089	.025	.183	.089	.025	.178	.087	.025	.173	.086	.024	.168	.085	.024		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.216	.216	.216	.185	.185	.185	.126	.126	.126	.073	.073	.073	.023	.023	.023	
1.0	.206	.177	.152	.176	.152	.131	.120	.105	.090	.069	.061	.053	.022	.020	.017	
2.0	.197	.150	.111	.169	.129	.096	.116	.089	.067	.067	.052	.039	.021	.017	.013	
3.0	.188	.130	.084	.161	.112	.073	.111	.078	.051	.064	.046	.030	.021	.015	.010	
4.0	.179	.115	.066	.154	.100	.058	.106	.069	.041	.061	.041	.024	.020	.013	.008	
5.0	.171	.104	.054	.147	.090	.047	.101	.063	.033	.059	.037	.020	.019	.012	.006	
6.0	.163	.094	.045	.140	.081	.039	.096	.057	.028	.056	.034	.016	.018	.011	.005	
7.0	.155	.086	.038	.133	.075	.033	.092	.052	.024	.053	.031	.014	.017	.010	.005	
8.0	.147	.080	.033	.127	.069	.029	.088	.049	.021	.051	.029	.012	.017	.009	.004	
9.0	.140	.074	.029	.121	.064	.026	.084	.045	.018	.049	.027	.011	.016	.009	.004	
10.0	.134	.069	.026	.115	.060	.023	.080	.042	.016	.047	.025	.010	.015	.008	.003	

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

Uncorrected UGR Table

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M					TYPE: /					WEIGHT: 0.325kg/m				
DIM.: 16*17mm					SPEC.:					SERIAL No.:				
MFR.:					SUR.: 16*1000mm					PROTECTION ANGLE: /				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3				
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3				
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				
Room dimensions					Viewed crosswise					Viewed endwise				
x = 2H y = 2H					15.8	17.3	16.1	17.5	17.7	15.0	16.6	15.3	16.8	17.0
3H					17.5	18.9	17.8	19.1	19.4	16.4	17.8	16.7	18.0	18.3
4H					18.2	19.6	18.5	19.8	20.1	16.9	18.2	17.2	18.5	18.7
6H					18.8	20.0	19.1	20.3	20.6	17.1	18.4	17.4	18.6	18.9
8H					18.9	20.2	19.3	20.5	20.8	17.1	18.3	17.4	18.6	18.9
12H					19.1	20.2	19.4	20.5	20.8	17.1	18.2	17.4	18.5	18.8
4H 2H					16.3	17.6	16.6	17.9	18.2	15.7	17.0	16.0	17.3	17.6
3H					18.2	19.3	18.5	19.6	20.0	17.2	18.4	17.6	18.7	19.0
4H					19.0	20.1	19.4	20.4	20.8	17.8	18.9	18.2	19.2	19.6
6H					19.7	20.7	20.1	21.0	21.4	18.1	19.1	18.5	19.5	19.8
8H					19.9	20.8	20.3	21.2	21.6	18.2	19.1	18.6	19.4	19.8
12H					20.1	20.9	20.5	21.3	21.7	18.1	19.0	18.6	19.4	19.8
8H 4H					19.2	20.1	19.6	20.5	20.8	18.1	19.0	18.5	19.4	19.8
6H					20.0	20.7	20.4	21.2	21.6	18.5	19.3	19.0	19.7	20.1
8H					20.3	21.0	20.8	21.4	21.9	18.6	19.3	19.1	19.7	20.2
12H					20.5	21.1	21.0	21.5	22.0	18.6	19.2	19.1	19.6	20.1
12H 4H					19.2	20.0	19.6	20.4	20.8	18.1	19.0	18.6	19.4	19.8
6H					20.0	20.7	20.5	21.1	21.6	18.6	19.3	19.1	19.7	20.1
8H					20.3	20.9	20.8	21.4	21.8	18.7	19.3	19.2	19.7	20.2
Variations with the observer position at spacings:														
S = 1.0H					+ 0.1 / - 0.2					+ 0.2 / - 0.2				
1.5H					+ 0.1 / - 0.2					+ 0.2 / - 0.3				
2.0H					+ 0.2 / - 0.3					+ 0.2 / - 0.4				

CIE Pub.117 Corrected 110.0 lm Total Lamp Luminous Flux. (8log(F/F0) = -7.7)

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) k(RI) x RCR = 5									
k = 0.60	64	51	43	64	51	43	62	50	43	36
0.80	76	62	54	75	62	54	73	61	53	45
1.00	85	72	64	84	72	64	81	73	63	55
1.25	93	81	73	92	80	72	88	79	71	63
1.50	99	87	79	97	86	79	93	84	78	69
2.00	107	97	89	105	95	88	101	93	87	78
2.50	111	102	95	109	101	94	104	98	92	82
3.00	115	107	101	113	105	99	108	102	97	87
4.00	120	113	108	117	111	106	112	107	103	93
5.00	122	117	112	120	115	110	115	110	107	96
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004										
Suspended										
SHRNOM = 1.25										

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
 γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /




C Range: 0 - 360DEG
 C Interval: 30.0DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: shan
 Test Date: 2018-09-06

γ Range: 0 - 180DEG
 γ Interval: 2.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
 Humidity: 45.0%
 Test Distance: 6.950m [K=1.0000]
 Remarks:

AAI Figure

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
 γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
 γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

Average Luminance Table(CIBSE)

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /

Parameter description for average Luminance	Symbol	Value	Unit
Luminance in Azimuth Plane	Bc	refer Table 2	cd/sq.m.
Intensity at angle Gamma in given azimuth plane	I	from data	cd/klm
Number of lamps	N	1	
Output of each lamp(initial lumens as specified)	F	110	lm
Multiplying factor	K	1	
Luminous area in horizontal plane used in calculations	A	0.016	sq.m.
Angle to the downward vertical from light centre	Gamma	from data	deg

Table 1. Calculation parameters for determination of CIBSE LG3:1996 Average Luminance

G	C plane(deg)																		
deg	0	10	20	30	40	50	60	70	80	90	100	110	120	130	140	150	160	170	180
55	2483	2420	2361	2305	2251	2203	2161	2127	2103	2092	2100	2121	2150	2186	2227	2273	2319	2368	2419
60	2448	2377	2310	2247	2184	2127	2078	2038	2011	1998	2007	2031	2065	2107	2156	2208	2258	2311	2369
65	2412	2330	2252	2178	2103	2036	1977	1933	1901	1885	1887	1906	1940	1995	2059	2129	2189	2252	2319
70	2372	2272	2178	2087	1997	1914	1842	1787	1748	1727	1728	1749	1789	1857	1937	2024	2096	2171	2252
75	2308	2184	2064	1948	1829	1720	1625	1554	1506	1483	1494	1528	1585	1664	1757	1857	1947	2044	2150
80	2183	2007	1838	1676	1509	1357	1225	1129	1064	1035	1054	1106	1185	1290	1411	1544	1665	1799	1951
85	1825	1526	1255	1014	798	614	463	349	275	243	274	343	440	543	668	817	976	1176	1432

Table 2. Average Luminance(cd/sq.m.) for defined C plane, Gamma angle

CIBSE Category	Gamma (deg)	Average Luminance		Patch Luminance	
		maximum calculated	specified maximum	maximum measured	specified maximum
Category 1	55 to 90	2483	200	---	500
Category 2	65 to 90	2412	200	---	500
Category 3	75 to 90	2308	200	---	500

Table 3. Tabulation of Average and Patch Luminance(cd/sq.m.) for defined CIBSE categories

No match

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: C-SFR-F22B-HB-D24CC-B-108-2835-1M	TYPE: /	WEIGHT: 0.325kg/m
DIM.: 16*17mm	SPEC.:	SERIAL No.:
MFR.:	SUR.: 16*1000mm	PROTECTION ANGLE: /

Table--1

UNIT: cd

C(°)	0	30	60	90	120	150	180	210	240	270	300	330							
γ (°)	0	42.8	42.8	42.8	42.8	42.8	42.8	42.8	42.8	42.8	42.8	42.8							
5	42.7	42.5	42.3	42.3	42.4	42.5	42.6	42.8	42.9	42.9	42.9	42.8							
10	42.1	41.6	41.3	41.2	41.3	41.6	41.9	42.3	42.7	42.7	42.6	42.4							
15	41.4	40.8	40.2	40.1	40.3	40.7	41.2	41.7	42.2	42.3	42.1	41.8							
20	39.9	39.1	38.3	38.1	38.4	38.9	39.6	40.4	41.0	41.1	40.9	40.5							
25	38.6	37.6	36.8	36.5	36.8	37.5	38.3	39.2	39.9	40.0	39.8	39.3							
30	36.3	35.1	34.1	33.7	34.1	34.9	35.9	37.0	37.9	38.0	37.7	37.2							
35	34.5	33.2	32.2	31.7	32.1	33.1	34.1	35.3	36.2	36.2	36.1	35.4							
40	31.5	30.1	28.9	28.4	28.8	29.9	31.0	32.4	33.4	33.3	33.3	32.5							
45	29.4	27.8	26.6	26.0	26.5	27.6	28.8	30.3	31.3	31.1	31.2	30.4							
50	25.9	24.3	23.0	22.3	22.9	24.0	25.3	26.8	27.9	27.8	27.7	27.0							
55	23.4	21.8	20.5	19.8	20.4	21.5	22.8	24.4	25.5	25.4	25.4	24.5							
60	19.6	18.0	16.6	16.0	16.5	17.7	18.9	20.6	21.7	21.6	21.6	20.7							
65	17.0	15.4	14.0	13.4	13.8	15.0	16.3	18.0	19.1	18.9	18.9	18.1							
70	13.0	11.4	10.1	9.45	9.79	11.1	12.3	14.0	15.1	15.1	15.0	14.1							
75	10.2	8.74	7.40	6.81	7.22	8.37	9.59	11.3	12.3	12.4	12.3	11.3							
80	6.07	4.66	3.40	2.88	3.29	4.29	5.42	7.17	8.19	8.37	8.19	7.18							
85	3.25	2.02	1.06	0.71	1.01	1.69	2.65	4.41	5.47	5.67	5.43	4.42							
90	0.00	0.05	0.05	0.00	0.02	0.10	0.06	0.73	1.54	1.70	1.49	0.55							
95	0.00	0.01	0.01	0.00	0.00	0.05	0.05	0.13	0.14	0.10	0.01	0.00							
100	0.00	0.00	0.00	0.00	0.00	0.02	0.03	0.09	0.00	0.00	0.00	0.00							
105	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.07	0.00	0.00	0.00	0.00							
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00	0.00	0.00							
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
125	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
135	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
145	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
155	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
160	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
165	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
170	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
175	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: shan
Test Date: 2018-09-06

γ Range: 0 - 180DEG
γ Interval: 2.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V1.0.257
Humidity: 45.0%
Test Distance: 6.950m [K=1.0000]
Remarks: